

City of Bradenton Water Reclamation Facility

Reportable Event Notification

Facility ID # FL 0021369-014-DW1P/NR

5-DAY NOTICE OF PERMIT LIMIT EXCEEDANCES

Report Date: 02/05/25

Permittee or Responsible Person Name: Alphonso Gwyn, WRF Superintendent

Telephone Number: Cell 941-290-9375

Facility Location: 1810 1st Street West Bradenton, FL 34208

Event Start Date & Time: 01/19/25 07:30

Event End Date & Time: 01/25/25 07:30

Event Description & Cause:

The City WRF had an exceedance on the EFD-01 single sample TN (limit = 6.0 mg/L) on 01/23/25 with a result of 6.5 mg/L and on 01/25/25 with a result of 6.9 mg/L. These high single sample results also caused a weekly average exceedance for TN (limit = 4.5 mg/L) with an average of 5.9 mg/L. The data was confirmed upon receipt of the laboratory report, received 02/05/24.

Corrective Action taken: N/A The City is working with an on-site consultant to review and improve process control. While making adjustments there is the potential for parameter exceedances.

Preventative Action Taken: The City is developing a master plan of facility improvements and is currently building an additional clarifier and injection well.

FDEP-Tampa Notified

Contact Person: Jessie Standridge

Date & Time: 02/05/25 11:50

Method of Notification:

☒ Email: Jessie.Standridge@FloridaDEP.gov

☐ Phone call: 813-470-5736

Manatee County Health Dept. Notified

Contact Person: Tom Larkin

Date: 02/0/25 11:50

Method of Notification:

☒ Email: Thomas.Larkin@flhealth.gov

☐ Phone: 941-708-8497